



# Existing Fuel Burning Equipment Safety Test Report

(Use separate form for each appliance)

Property Address: \_\_\_\_\_ Date: \_\_\_\_\_

Property Owner: \_\_\_\_\_

**TYPE OF FUEL BURNING APPLIANCE (check one):**

Gravity Air	Forced Air	Gravity Hot Water	Forced Hot Water
Steam	Unit Heater	Space Heater	Other
<b>TYPE OF FUEL (check one)</b>	Gas	Oil	Other

**GAS DESIGN**

**CONVERSION**

Make of Burner	Make
Model	Model
Serial	Max. BTU Rating
Input	Make of Furnace

**EQUIPMENT VENTING TYPE**      Atmospheric      Induced Fan      Other

Total BTU input of all vented gas appliances per chimney

Type of Chimney: Masonry      Class B      Other

Type of Liner: None      Metal      Clay Tile

Combustible Air Supply: N/A      Yes      Recommended

**Safety & Operating Control Tests**      Yes      No      Fuel Analysis/Flue Gas Analysis      Yes      No

Pilot/Flame Safeguard Operating Properly			Vents Properly Without Spillage		
Limit(s) Operating Properly			Flame Stays inside/Doesn't Roll Out		
Operator(s) Operating properly			Burner Lights Smoothly		
Low Water Cut-Off Operating Properly					
All Controls Operating Properly					

**Initial      Final      Visual Inspection      Yes      No**

Stack Temperature	F/Net	F/Net	Fuel Piping Systems—Okay		
Oxygen	%	%	Vent Systems—Drafthood		
Carbon Dioxide	%	%	Connector, Vent Chimney—Okay		
Carbon Monoxide	%/ppm	%/ppm	Heating Unit—Okay		
Carbon Monoxide Detector (tube type)	Positive	Negative			

Look at total heating system before you leave: Does the system operate safely and properly?      Yes      No

**COMMENTS:** \_\_\_\_\_

**Have above corrections been made?**    Yes \_\_\_\_ No \_\_\_\_ N/A \_\_\_\_ Contractor License # \_\_\_\_\_

Name of Licensed Contractor: \_\_\_\_\_ Phone# \_\_\_\_\_

Address: \_\_\_\_\_

Person performing test: \_\_\_\_\_

(Print Name)

(Signature)

**\*\* FAILED TESTS MUST BE FAXED TO 651-747-2550 OR EMAILED TO [nspfd@northstpaul.org](mailto:nspfd@northstpaul.org) IMMEDIATELY. FOR QUESTIONS - CALL THE NORTH ST. PAUL FIRE DEPARTMENT AT 651-747-2405 \*\***