



**NORTH
ST. PAUL**
extraordinary.

Backflow Preventer Test Report

Address: _____

Contact Person: _____

Phone: _____

Device Location: _____

What System Does It Serve? _____

Make: _____

Model #: _____

Size: _____

Serial #: _____

Install Date _____

Overhaul Date _____

Test Date _____

**#1 Check Valve
PSI/DIFF**

**Relief
PSI/DIFF**

#2 Check Valve

Test Before Repairs

Final Test

Test Performed By: _____

Certification #: _____

Company Name: _____

License #: _____

Address: _____

Phone: _____

City: _____

St: _____

Zip: _____

Contact: _____

When there are NO Backflow Preventers, please check the box and have the form signed by the property owner or manager.

No Backflow Preventers

Name: _____

Date: _____

Filing Fee: \$25 per device

Continued on next page...



Backflow Preventer Testing Requirements

Backflow Preventers are devices that protect the water supply from contamination from substances that, if ingested, could be harmful to human health.

Minnesota State Plumbing Code outlines required backflow protection. Refer to the 2015 Minnesota Plumbing Code Parts 603.5.23 through 603.5.23.4

Link to Minnesota Plumbing Code Backflow Fact Sheet:

http://www.dli.mn.gov/cclD/PDF/fs_backflow.pdf

These devices are required to be tested and tagged annually. Written records of testing and maintenance must be maintained and submitted to the appropriate administrative authority, in this case the City of North St. Paul.

If you have Backflow Prevention Devices, please submit copies of the required annual testing / service reports. If you do not have the records, contact the Company you have perform your testing and request the copies from them. If you are not current with the testing, the form on the reverse side must be completed by an inspector certified to perform the Backflow tests.

All property owners, residential or commercial, are held liable by the United States Environmental Protection Agency (EPA) 1974 Safe Drinking Water Act for any injury resulting from a backflow incident under their control.

